



Product Service

CERTIFICATE

No. Z2 09 04 48107 009

Holder of Certificate: Bosch Security Systems B.V.Kapittelweg 10
4827 HG Breda
THE NETHERLANDS**Production
Facility(ies):**

67663, 10591

Certification Mark:**Product:**EVAC Unit
(Voice Alarm Control and Indicating Equipment)**Model(s):**

Praesideo V3.3

Parameters:Rated voltage: 100-120/220-240 V AC
Rated frequency: 50-60 Hz
Protection class: I

Remark:

The final installation is not covered by this certificate. The installation of this certified product has to be carried out by a qualified and authorized company following the mentioned standards of this certificate. This has to be confirmed by filling out the manufacturer's installation check list.

Tested according to:EN 54-16:2008
ISO 7240-16:2007
EN 60849:1998
BS 5839-8:1998

The listed product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. The certification mark must not be altered in any way. See also notes overleaf.

Test report no.:

028-71346646-000

Date, 2009-04-08

Page 1 of 1

